

July 9, 2026

ITEM NO.: 16

FILE NO.: Z-10326

NAME: Rezoning from R-4 to R-5

LOCATION: 5622 "B" Street

DEVELOPER:

Paulin Justin Harrison
12700 NE 8th St., Apt. E202
Bellevue, WA 98005

OWNER/AUTHORIZED AGENT:

Paulin Justin Harrison - owner
Nick Tucker - agent

SURVEYOR/ENGINEER:

Tucker Land Surveying
P.O. Box 1021
Cabot, AR 72023

AREA: 0.21-acre

NUMBER OF LOTS: 1

FT. NEW STREET: 0 LF

WARD: 3

CURRENT ZONING: R-4

VARIANCES:

None requested.

A. PROPOSAL/REQUEST/APPLICANT'S STATEMENT:

The property owner requests to rezone the 0.21-acre property located at 5622 "B" Street from "R-4" Two-Family District to "R-5", Urban Residence District.

B. EXISTING CONDITIONS:

The property contains a two-story, split-level, residential structure which contains multiple living units. There are two (2) parking pads/drives in the front yard area with parking for four (4) vehicles.

C. NEIGHBORHOOD NOTIFICATIONS:

All owners of property located within 300 feet of the site and all neighborhood associations registered with the City of Little Rock were notified of the public hearing.

D. ENGINEERING COMMENTS (PLANNING DIVISION):

No Comments.

ENGINEERING COMMENTS (PUBLIC WORKS):

No Comments.

E. UTILITIES/FIRE DEPARTMENT/PARKS/COUNTY PLANNING:

Little Rock Water Reclamation Authority: No comments.

Entergy: No comments received.

Summit Utilities: No comments.

AT & T: No comments received.

Central Arkansas Water:

All Central Arkansas Water requirements in effect at the time of request for water service must be met.

Fire Department:

Must Comply with Arkansas Fire Prevention Code 2021 edition

All projects submitted for zoning approval must comply with the Arkansas Fire Prevention Code, 2021 Edition, including any comments or requirements provided by the Little Rock Fire Marshal's Office, prior to acceptance.

Maintain Access:

Fire Hydrants.

Maintain fire apparatus access roads at fire hydrant locations as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 **Section D103.1 Access road**

width with a hydrant. Where a fire hydrant is located on a fire apparatus access road, the minimum road width shall be 26 feet, exclusive of shoulders.

Grade

Maintain fire apparatus access roads as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 **Section D103.2 Grade. Fire apparatus access roads shall not exceed 10 percent in grade except as approved by the fire chief. If the grade exceeds 10 percent, approval will be denied and the applicant must submit request to be reviewed by Fire Chief for Approval.**

Loading

Maintain fire apparatus access road design as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 **Section D102.1 Access and loading.** Facilities, buildings or portions of buildings hereafter constructed shall be accessible to fire department apparatus by way of an approved fire apparatus access road with asphalt, concrete or other approved driving surface capable of supporting the imposed load of fire apparatus weighing at least 75,000 pounds.

Commercial and Industrial Developments – 2 means of access. - Maintain fire apparatus access roads as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1

Section D104.1 Buildings exceeding three stories or 30 feet in height. Buildings or facilities exceeding 30 feet or three stories in height shall have at least two means of fire apparatus access for each structure.

Section D104.2 Building exceeding 62,000 square feet in area. Buildings or facilities having a gross building area of more than 62,000 square feet shall be provided with two separate and approved fire apparatus access roads.

Exception: Projects having a gross building area of up to 124,000 square feet that have a single approved fire apparatus access road when all buildings are equipped throughout with approved automatic sprinkler systems.

D104.3 Remoteness. Where two fire apparatus access roads are required, they shall be placed a distance apart equal to not less than one half of the length of the maximum overall diagonal dimension of the lot or area to be served, measured in a straight line between accesses.

30' Tall Buildings - Maintain aerial fire apparatus access roads as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 Section D105.1 – D105.4

D105.1 Where Required. Where the vertical distance between the grade plane and the highest roof surface exceeds 30', approved aerial fire apparatus access roads shall be provided. For the purposes of this section the highest roof surfaces shall be determined by measurement to the eave of a pitched roof, the intersection of a roof to the exterior wall, or the top of the parapet walls, whichever is greater.

D105.2 Width. Aerial fire apparatus access roads shall have a minimum unobstructed width of 26', exclusive of shoulders, in the immediate vicinity of the building or portion thereof.

D105.3 Proximity to building. At least one of the required access routes meeting this condition shall be located within a minimum of 15 feet and a maximum of 30 feet from the building and shall be positioned parallel to one entire side of the building. The side of the building on which the aerial fire apparatus access road is positioned shall be approved by the fire code official.

D105.4 Obstructions. Overhead utility and power lines shall not be located over the aerial fire apparatus access road or between the aerial fire apparatus road and the building. Other obstructions shall be permitted to be placed with the approval of the fire code official.

Dead Ends.

Maintain fire apparatus access roads at dead end locations as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 Section D103.4 Dead Ends. Dead-end fire apparatus access roads in excess of 150 feet shall be provided with width and turnaround provisions in accordance with Table D103.4. Requirements for Dead-end fire apparatus access roads.

Gates

Maintain fire apparatus access road gates as per Appendix D of the 2021 Arkansas Fire Prevention Code Vol. 1 Section D103.5 Fire apparatus access road gates. Gates securing the fire apparatus access roads shall comply with all of the following criteria:

1. Minimum gate width shall be 20 feet.
2. Gates shall be of swinging or sliding type.
3. Construction of gates shall be of material that allow manual operation by one person.
4. Gate components shall be maintained in an operable condition at all times and replaced or repaired when defective.

5. Electric gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. Emergency opening devices shall be approved by the fire code official.
6. Manual opening gates shall not be locked with a padlock or chain and padlock unless they are capable of being opened by means of forcible entry tools or when a key box containing the keys to the lock is installed at the gate location.
7. Locking device specifications shall be submitted for approval by the fire code official
8. Electric gate operators, where provided, shall be listed in accordance with UL 325.
9. Gates, intended for automatic operation, shall be designed, constructed and installed to comply with requirements of ASTM F 2200.

Multi-Family Residential Developments

As per Appendix D, Section D106.1 of the 2021 Arkansas Fire Prevention Code Vol. 1. Projects having more than 100 dwelling units. Multiple-family residential projects having more than 100 dwelling units shall be equipped throughout with two separate and approved fire apparatus access roads.

Exception: Projects having up to 200 dwelling units may have a single approved fire apparatus access road when all building, including nonresidential occupancies are equipped throughout with approved automatic sprinkler systems installed in accordance with Section 903.3.1.1 or 903.3.1.2

As per Appendix D, Section D106.2 of the 2021 Arkansas Fire prevention Code Vol. 1. Projects having more than 200 dwelling units. Multiple-family residential projects having more than 200 dwelling units shall be provided with two separate and approved fire apparatus access roads regardless of whether they are equipped with an approved automatic sprinkler system.

Parks and Recreation: No comments received.

F. BUILDING CODES/LANDSCAPE:

Building Codes: No comments received.

Landscape: No Comments.

G. TRANSPORTATION/PLANNING:

Rock Region Metro: No comments received.

Planning Division:

Land Use Plan:

The request is in Planning District 4, the Heights/Hillcrest Planning District. The development principles of this district advocate preservation and enhancement of the unique and positive features of this section of the city. The Land Use Plan shows Residential High Density (RH) for the application area. The Residential High Density (RH) category accommodates residential development of more than twelve (12) dwelling units per acre.

To the north of the application area is area designated for Residential Low Density (RL) uses and is characterized by single-family residences interspersed with duplexes. To the east, south, and west of the application area are areas designated for Residential High Density (RH) uses and are characterized by apartment buildings with 3-6 units and 7-20 units, duplexes, and single-family residences.

The subject site is located in the Hillcrest Design Overlay District (Ord. 20223). The purpose of the Hillcrest Design Overlay District is to maintain the built environment of a neighborhood that is rich in history and architectural character that consists of both a vital residential area and a thriving commercial sector.

Master Street Plan:

B Street is a Local Street on the Master Street Plan. Local Streets are roads designed to provide access to adjacent property with the movement of traffic being a secondary purpose. The standard Right-of-way is 50'. Sidewalks are required on one side. This street may require dedication of right-of-way and may require street improvements.

Bicycle Plan:

B Street is not shown on the Master Bike Plan with existing or proposed facilities in this area.

Historic Preservation Plan:

The application, as shown, should have no effect on identified historic resources.

H. Analysis:

The property owner requests to rezone the 0.21-acre property located at 5622 "B" Street from "R-4" Two-Family District to "R-5", Urban Residence District.

The property contains a two-story, split-level, residential structure which contains multiple living units. There are two (2) parking pads/drives in the front yard area with parking for four (4) vehicles.

The City's Future Land Use Plan designates this property as "RH" Residential High Density. The requested R-5 zoning does not require an amendment to the plan.

Staff is supportive of the requested rezoning. Staff views the request as reasonable. The proposed R-5 zoning will be consistent with the zoning pattern in the immediate area. The adjacent properties to the east and west, and across "B" Street to the south are currently zoned R-5.

I. STAFF RECOMMENDATION:

Staff recommends approval of the requested R-5 rezoning.

PLANNING COMMISSION ACTION:

(July 9th, 2026)

The applicant was present. There were no objectors present. The application was placed on the Consent Agenda for approval as recommended by staff.

There was a motion to approve the Consent Agenda. The motion passed by a vote of 9 ayes, 1 nays and 1 absent. The application was approved.